

Carderock Division Naval Surface Warfare Center

Bethesda, Maryland 20084-5000

CARDIVNSWC-TR-82-93/47 October 1993

Machinery Research and Development Directorate
Research and Development Report

Computer Analysis of Fuel Cell Power Systems Performance for Naval Applications

by
Robert E. Smith



PROCESSED

Approved for public release; distribution unlimited.

JUL 06 1998

07 JAN 1994

10# 596520

R024739

19980917 041

MAJOR NSWC/CARDEROCKDIV TECHNICAL COMPONENTS

- CODE 011 DIRECTOR OF TECHNOLOGY, PLANS AND ASSESSMENT
- 12 SHIP SYSTEMS INTEGRATION DEPARTMENT
 - 14 SHIP ELECTROMAGNETIC SIGNATURES DEPARTMENT
 - 15 SHIP HYDROMECHANICS DEPARTMENT
 - 16 AVIATION DEPARTMENT
 - 17 SHIP STRUCTURES AND PROTECTION DEPARTMENT
 - 18 COMPUTATION, MATHEMATICS & LOGISTICS DEPARTMENT
 - 19 SHIP ACOUSTICS DEPARTMENT
 - 27 PROPULSION AND AUXILIARY SYSTEMS DEPARTMENT
 - 28 SHIP MATERIALS ENGINEERING DEPARTMENT

CARDEROCKDIV/NSWC ISSUES THREE TYPES OF REPORTS:

1. **NSWC/CARDEROCKDIV reports, a formal series**, contain information of permanent technical value. They carry a consecutive numerical identification regardless of their classification or the originating department.
2. **Departmental reports, a semiformal series**, contain information of a preliminary, temporary, or proprietary nature or of limited interest or significance. They carry a departmental alphanumeric identification.
3. **Technical memoranda, an informal series**, contain technical documentation of limited use and interest. They are primarily working papers intended for internal use. They carry an identifying number which indicates their type and the numerical code of the originating department. Any distribution outside NSWC/CARDEROCKDIV must be approved by the head of the originating department on a case-by-case basis.

CONTENTS

| | |
|---|-----|
| FIGURES | iii |
| ABBREVIATIONS | iv |
| ABSTRACT | 1 |
| ADMINISTRATIVE INFORMATION | 1 |
| INTRODUCTION | 2 |
| Definition | 2 |
| Fuel cell advantages in naval applications | 2 |
| Advantages Unique to Fuel Cells | 2 |
| Overall Thermal Efficiency | 2 |
| System Weight and Volume | 3 |
| System Cost | 4 |
| SCOPE | 4 |
| COMPUTER PROGRAM DESCRIPTION | 5 |
| Overall Program Operation | 5 |
| Anode Operation | 5 |
| Cathode Operation | 5 |
| Water management system | 7 |
| Operation of the Design Program | 7 |
| Input data | 7 |
| First approximations | 7 |
| Material and energy balance | 7 |
| Heat exchanger design | 9 |
| Cost estimates | 9 |
| Weight and volume calculations | 9 |
| Off design data | 9 |
| TYPICAL FUEL CELL POINT DESIGNS | 10 |
| The System Design Program, DTRC7-R5. | 10 |
| Heat Exchanger Modules, HXNET-1B, HXNET-2B, and HXNET-3B | 11 |
| Cost Estimating, ECON7 | 12 |
| Determining component and system weights and volumes, WT-VOL7 | 14 |
| Off-Design Module Operation, DTRC7-OD | 16 |
| 3-D MODELING BY COMPUTER AIDED DESIGN | 17 |
| CONCLUSIONS | 19 |
| RECOMMENDATIONS | 20 |
| APPENDIX A: Example of PEM design data for ship impact study | 21 |
| APPENDIX B: Example of PAFC design data for ship impact study | 22 |
| APPENDIX C: Example of MCFC design data for ship impact study | 23 |

FIGURES

| | | |
|------------|---|----|
| Figure 1. | Comparison of the effect of load on performance. | 3 |
| Figure 2. | Schematic of a typical PEM fuel cell power system using auto thermal reforming. | 6 |
| Figure 3. | Computer generated diagram of flow schematic showing nodes used in system design and analysis. | 6 |
| Figure 4. | Algorithm for a typical design program, DTRC7-R5. | 8 |
| Figure 5. | Initial data screen display, DTRC7-R5. | 10 |
| Figure 6. | Initial conditions display screen. | 11 |
| Figure 7. | Sample node array of the system design module DTRC7-R5. | 11 |
| Figure 8. | Heat exchanger design output matrix. | 12 |
| Figure 9. | Typical heat exchanger design output screen. | 12 |
| Figure 10. | Example of process contingency cost screen. | 13 |
| Figure 11. | Example of project contingency cost screen. | 13 |
| Figure 12. | Example of the contingency cost summary screen. | 14 |
| Figure 13. | Example of cost summary screen. | 14 |
| Figure 14. | Example of system weight summary screen. | 15 |
| Figure 15. | Example of the system volume summary screen. | 15 |
| Figure 16. | Example of heat exchanger weight and volume analysis. | 15 |
| Figure 17. | Example of balance of plant weight and volume analysis. | 16 |
| Figure 18. | Example of the set-up screen for off-design analysis. | 16 |
| Figure 19. | Example of the off-design data summary screen. | 17 |
| Figure 20. | 3-dimensional model of the 2500 kW fuel cell power system. | 18 |

ABBREVIATIONS

| | |
|-----------------|-----------------------------------|
| ATM | Atmosphere |
| ATR | Auto thermal reformer |
| BOP (B.O.P.) | Balance of plant |
| BTU (B) | British Thermal Unit |
| CAD | Computer aided design |
| COMP | Compressor |
| CORP | Corporation |
| C _p | Heat capacity (constant pressure) |
| DEG | Degree |
| F | Fahrenheit |
| FLO | Flow |
| FO | Fuel Oil |
| ft ² | Square foot |
| ft ³ | Cubic foot |
| GAL | Gallon |
| GEN | Generator |
| H | Enthalpy |
| HDS | Hydro desulfurizer |
| HR | Hour |
| HRS | Hours |
| HX | Heat exchanger |
| in ² | Square inch |
| k | Killo |
| kW | Killowatt |
| kWh | Killowatt hours |
| LB | Pound |
| LOX | Liquid oxygen |
| M | Mole |
| MAT'L | Material |
| MCFC (MC) | Molten carbonate fuel cell |
| MPH | Mole per hour |
| MW | Megawatt |
| P | Pressure |
| PAFC (PA) | Phosphoric acid fuel cell |
| PEM | Polymer exchange fuel cell |
| REFMR | Reformer |
| SAT | Saturator |
| SOFC (SO) | Solid oxide fuel cell |
| SWBS | Ship work breakdown structure |
| S/O | Selective oxidized |
| T | Temperature |
| TURB | Turbine |
| VS | Versus |

ABSTRACT

This report demonstrates the use of computer programs to model and analyze fuel cell power systems for ship applications which utilize hydrocarbon fuels. Programs available include those for Molten Carbonate (MCFC), Phosphoric Acid (PAFC), and Polymer Exchange Membrane (PEM). The PEM system was chosen as an illustrative example because the program for the PEM model is the most comprehensive of the available programs. It has been recently employed extensively in a ship impact study conducted by the Carderock Division, Naval Surface Warfare Center (CDNSWC).

The development of a 2500kW PEM fuel cell power system is described in detail beginning with functional input requirements and ending with a complete physical model. The model includes the size and weight of all major power plant components required to produce direct current electric power with diesel fuel. The fuel cell system weights and volumes are compared to state-of-the-art gas turbine and diesel engine generators. Fuel utilization curves are generated and compared with typical equivalent engine generator systems.

The output of each phase of development is exhibited as the program is run. For example: the system architecture, material balances, energy balances, detailed heat exchanger utilization and design data, acquisition and life cycle cost estimates, component weights and volumes, and off-design performance (fuel rate versus per cent rated load data). A three dimensional computer model of the system is drawn from the generated data showing the major components in relative positions using AutoCad[™]. This model can be utilized in other AutoCad[™] compatible programs to demonstrate the spatial arrangement of components within the ship and to estimate centers of gravity and moments.

Recommendations stemming from this study include: creating a module for SOFC technology; and modifying the existing modules to include bottoming cycles, optimization for maximum water recovery, and updated heat exchanger designs and materials.

ADMINISTRATIVE INFORMATION

This report is submitted in partial fulfillment of Milestone 1, Task 4 of the Mechanical Power and Auxiliary System Project (RN21E42). The work herein was sponsored by the Office of Naval Research (ONR 4524) and performed by the Fluid Systems and Machinery Analysis Branch, Code 824, of the Power Systems Department, Machinery Research and Development Directorate, Naval Surface Warfare Center, Carderock Division, Annapolis Detachment. The computer programs referred to in this report were developed by Analytic Power Corporation under NSWC Contracts N61533-89-C-0008, N61533-90-C-0043 and N61533-91-C-0101. The authors also acknowledge NAVSEA 03R17 for sponsoring fuel cell studies which utilized these programs.

INTRODUCTION

Definition

A fuel cell is an electrochemical device, similar to a battery, which converts fuels such as natural gas or heating oil to electricity without combustion and without generation of noise. Fuel cell power systems have no moving parts except for a few pumps and blowers. Electric power generators are consist of many fuel cells connected together to form large arrays as required to meet the power demands.

Fuel cell advantages in naval applications

In preliminary ship power studies¹, fuel cell power plants have shown distinct advantages over conventional maritime gas turbines and diesel plants. These advantages include higher efficiency and reduced weight and volume. In addition to these benefits, it was also predicted that ship service power and propulsion power installations based on a fuel cell power plant design, and incorporated into a Navy vessel's design, may realize cost savings as the price of less polluting fuels and fines levied for air pollution increase in the future.

Advantages Unique to Fuel Cells

The minimum amount of moving components, intrinsic non-magnetic materials of construction, and inherent high thermal efficiency combine to give the Navy three advantages not met by any other power generating system:

- Stealth
- High Fuel Economy (lower fuel costs/longer missions)
- Essentially Zero Pollution

Overall Thermal Efficiency

As fuel cells are electrochemical devices, not heat engines, they are not subject to Carnot efficiency limitations, and can achieve very high efficiencies at moderate temperatures with appropriate design. A conservatively designed fuel cell power plant can exceed gas turbine and diesel efficiencies by several percentage points. An even more important benefit in efficiency is attained in the off design case. Standard Navy practice requires a backup generator to be at idle in case of the failure of the prime power unit. Two ship service power plants are therefore usually run at half power. Gas turbine and diesel engines running at half power lose efficiency. The efficiency of fuel cells, on the other hand, increases as loads are reduced from full load.

The effect of off-design operation on overall thermal efficiency for various engine generator systems using diesel fuel is compared in Figure 1. The Allison 501-K34 gas turbine, presently used as the ship service generator on many Navy ships has a design point efficiency of roughly 33%; this drops to about 25 % at half power. By comparison, the efficiency of a 2500 kW PEM system, the uppermost curve on Figure 1, is projected to be 5 percentage points higher than the intercooled regenerative (ICR) gas turbine engine generator, and 17 percentage points higher

¹ Boughers, Ward, et al., *The Assessment of Fuel Cell Power Plants for Surface Combatants: Final Report*, CARDIV-TM-(not numbered), in publication.

than the LM2500 engine generator. The efficiency of the PEM system is very flat over the load range.




Figure 1. Comparison of the effect of load on performance.

System Weight and Volume

Initial studies indicated that fuel cells power plants by themselves can be made lighter than comparable gas turbines or diesel plants. Further studies indicated that in the context of the entire power system and support equipment, these savings will be even more dramatic. Support equipment includes such things as exhaust and inlet stacks, gearing, foundations, operating fluids and lubricants, and fuel service system. Based on the Ship Breakdown Structure (SWBS) for an Arleigh class vessel, the gas turbine engines themselves make up only a small part of the total weight, volume and cost of a main propulsion or ship service power system.

System Cost

It is unlikely that fuel cell systems are competitive today with equivalent engine generator systems strictly on a cost basis at the present time due to the immature nature of the technology. Some inherent fuel cell design features, however, indicate significant cost saving in the immediate future, given the present direction of environmental and energy policies.

Modular design, low thermal emission, and low pollution allow fuel cell systems to be placed in inhabited spaces and arranged to suit the space available. This modular nature also permits great flexibility in meeting the inevitable increasing power demands. Instead of designing a new engine or modifying an existing engine, the fuel cell system power can be increased by simply adding modules. It is beyond the scope of this report to estimate these cost savings, but they should be significant.

Fuel cell systems operate on hydrogen. The source of this hydrogen is insignificant except as it affects storage and handling. Surface naval requirements dictate systems which can operate with diesel fuel while submersibles might use a synthetic fuel such as methanol. In all cases a processor to convert the fuel to hydrogen is an integral part of the system. This contrasts with some utilities in the United States and Japan which use fuel cells operating with natural gas, kerosene, coal gas, and similar fuels. The design and complexity of a fuel cell power generating system, and, therefore, the costs, depends on the application and the type of fuel available.

As more synthetic and renewable fuels become available and possibly mandatory due to air quality requirements in the future, the cost effectiveness of fuel cell power systems aboard ships will increase dramatically because the stacks will not be effected or require modification.

SCOPE

The Center has been extensively involved in the design and analysis of fuel cell power systems for Naval applications and is presently investigating the impact of various systems on ship design. Toward this end, a suit of computer aided design programs were developed under contract from the Analytic Power Corporation². These programs assist engineers in the design of complete power plants based on the net power production required. Data from these programs can be used to analyze the effects of parameter modifications on the plant weight, size, and efficiency. The data can also be used to produce 3-dimensional computer models of specific power plants, within which, components may be visualized and spatially arranged for available spaces, such as; ship engine rooms, auxiliary spaces, and an infinite number of other arrangements useful in making ship impact assessments.

This report endeavors to demonstrate the power of the Analytic Power Corp. computer programs in designing a broad range of fuel cell power systems. A specific example of designing a 2500 kW PEM system, concluding with the production of a 3-dimensional AutoCad[®] model is employed to illustrate the result of the process.

² Friedhoff and Bloomfield, *ANALYTIC POWER CORPORATION FINAL REPORT C055 FUEL CELL SYSTEMS STUDIES*, Contract No. N61533-91-C-0101, April 1992.

COMPUTER PROGRAM DESCRIPTION

The following is an example of using a typical design program using the Analytic Power Corp. modules for PEM fuel cell power systems. The source modules include the following sub modules which are automatically concatenated during program execution of the main module:

- DTRC7R5 .BAS Main program, fuel cell and stack design module, and sub program manager
- FC_TAP .BAS Design data storage and handling module
- HXNET1 .BAS Heat/energy balance
- HXNET2 .BAS Heat management architecture
- HXNET3 .BAS Heat exchanger and condenser design module
- ECON7 .BAS Cost estimating module
- WT-VOL7 .BAS Balance of plant (reformer, shift converter, desulfurizer, and saturators) design, and heat exchanger and condenser weight and volume sizing
- DTRC7_OD.BAS Off-design performance prediction.

The modules are written in BASIC (Quick Basic 2) and are compiled to executable form from which they are executed.

Overall Program Operation

The design of fuel cell systems utilizing an auto thermal reformer assumes the overall fluid flow pattern shown in Figure 2. Figure 3 shows the diagram which appears on the computer screen as the program executes. The numerals in parenthesis represent nodes with which the computer determines the material and energy balances.

The system operation can best be comprehended by following the flow schematic in Figure 3 while reading the description below.

Anode Operation. Fuel (node 1) is pumped to system pressure, pre-heated and vaporized in the ATR. At the ATR inlet (node 3) fuel vapor is mixed with spent air from the cathodes of the fuel cell stack containing unreacted oxygen. This oxygen is used to burn some of the fuel creating heat for the thermal reforming process which liberates hydrogen (H_2) from the fuel and produces carbon dioxide (CO_2) and carbon monoxide (CO). Sulfur is converted to hydrogen sulfide (H_2S) in the highly reducing atmosphere. The hot reformat enters the heat exchanger (node 4) giving up much of its heat to the cooler incoming air and then enters a system of zinc oxide (ZnO) beds which adsorbs the H_2S . The desulfurized gas enters the shift converter (SHIFT) (node 25) where CO, reacts with steam producing CO_2 and H_2 . The hydrogen rich stream passes through a selective oxidizer (SO) where any remaining CO is converted to CO_2 . The gas then enters the anode saturator (SAT) where it is contacted with water (node 26 to 27) before entering the anode manifold of the fuel cell stack (node 5). In the anode flow fields of the cells, hydrogen is electrochemically converted to hydrogen ions which migrate through the membrane electrolyte to the cathode flow field. If the computer deems conditions to be favorable, excess water may be condensed from the anode gases prior to exiting at node 6. The spent anode gas is mixed with compressed inlet air in a catalytic burner where the remaining hydrogen is oxidized. This reaction raises the temperature of the exhaust (node 14) for operation of the turbocharger. The exhaust is then ducted to the atmosphere.

Cathode Operation. Ambient air entering the turbocharger (node 7) is compressed to the operating pressure (node 8) designated in the set up parameters.




Figure 2. Schematic of a typical PEM fuel cell power system using auto thermal reforming.




Figure 3. Computer generated diagram of flow schematic showing nodes used in system design and analysis.

The pressurized air is saturated with water prior to entering the cathode manifold (node 10). As air passes through the cathode flow fields in the cells, oxygen is reacted electrochemically with hydrogen ions migrating through the membrane from the anode, producing water. Water produced in the fuel cell reaction is removed from the air stream in a sea-water cooled condenser (not shown on the schematic) and retained in the water management system (node 29). The air (node 11) is heated in the heat exchanger with gases from the ATR before entering the ATR (node 12).

Water management system. The water produced in the cells is essentially pure. Water is circulated through the cathode saturator (node 17) where it contacts the inlet air and then to the cooling manifold of the cell stacks. The temperature of the water is increased as it passes through the flow fields of the cells and removes excess heat. The heated water (node 19) then enters the anode saturator where it saturates the hydrogen rich anode stream. Water remaining in the loop (node 20 to 16) is cooled in a ship raw water heat exchanger. This accounts for most of the heat rejection in the system.

Operation of the Design Program.

The following gives a description of the execution of the computer programs in the design and analysis of a fuel cell power system. Figure 4 shows an algorithm of the overall program functions in block form to simplify explanation.

Input data. The operator begins execution by running "DTRC7R5". The first screens contain the initial parametric data which the operator may change as required. The following parameters are variable.

- Net power, kW (in most modules)
- Mechanical efficiency, percent (pumps, blowers, etc.)
- System pressure, Atm
- Cell voltage (affects efficiency and current density)
- Cell inlet temperature, deg F
- Hydrogen utilization, percent
- Water to carbon ratio in reformer (affects reformer efficiency)

First approximations. Average cell performance is predicted from the input conditions applied and the polarization curve data of the system involved. The polarization curves vary greatly with fuel cell technology. Then the stack performance is computed and compared with the required net power. If the comparison is not within design parameters, adjustments to the number of cells, cells per stack, and cell active area is modified and the process reiterated.

Material and energy balance. When the stack design meets the required parameters the program begins determination of the overall material balance. To obtain the necessary balance the size and performance of the fuel processing equipment is modified. When a balance is obtained, an energy balance is attempted. To attain a correct balance the gross power is modified and the cell and stack design is reiterated. These processes continue until both the material and energy balances.




Figure 4. Algorithm for a typical design program, DTRC7-R5.

At this point, the following outputs are available:

- Net power
- Exhaust temperature
- Exhaust flow rate
- Exhaust composition
- Air flow rate
- Sea water flow rate

Heat exchanger design. The operation of the heat exchanger design sub program is extremely complex and well beyond the scope of this report. It is sufficient to state that the program designs appropriate heat exchangers and arranges their placement in the flow schematic for maximum efficiency. A diagram of the heat exchanger system is available to the operator on demand.

Cost estimates. The cost estimation sub program is straight forward and is very comprehensive. Cost estimates include acquisition costs, developmental costs of various contingencies from prototype to final production units, operational costs, and costs involved in buying (eg. cost of money, etc.), installation, and maintenance (40-year depreciation). This sub program was written by Analytic Power Corp. for the electric power industry applications and includes information not particularly applicable to Navy needs. Data available and usually recorded at this point includes:

- Stack cost
- Balance of plant cost
- Life cycle cost

Weight and volume calculations. The calculation of hardware weight and volume is straight forward and involves using data generated in the design sub programs to determine the volume of various equipment. A table of weight factors and material densities are used in conjunction with standard practices with regard to pressure vessel and heat exchanger design to establish the final weight data. The following data is available:

- Weight and volume of;
 - Stack
 - BOP,
 - Reformer
 - Shift converter
 - Desulfurization equipment
 - Heat exchangers
 - Condensers
- Equivalent weight and volume
 - Gas turbine generator set
 - Diesel engine generator set

Off design data. After completion of the initial design program, the performance prediction module can be executed to obtain the performance of the design at various power levels. This module is essentially a modified version of DTRC7R5.bas where the size of hardware is fixed and the temperatures, pressures and flow rates are allowed to vary according to the applied load. The most important information from this module is the fuel rates at selected loads which can be used to obtain specific fuel consumption curves.

TYPICAL FUEL CELL POINT DESIGNS

Point design modules for PEM, MCFC, and PAFC fuel cell systems were developed and updated by Analytic Power Inc. under Navy contract (see page). Recently they were used to produce designs and data for a ship impact study where the beneficial assets of fuel cells could be evaluated when applied to a theoretical surface ship. Some examples of these point design data spread sheets for PEM, PAFC, and MCFC systems are shown in Appendices A, B, and C, respectively.

The following example of a typical point design uses the PEM technology. PEM technology was chosen because it represents the technology for which the most comprehensive analytic programs have been developed at present. Software facilities now include all the existing fuel cell technologies except solid oxide (SOFC). SOFC development is in the early stages at this time and a viable model for both planar and tubular technologies will be developed in the near future.

The System Design Program, DTRC7-R5.

At the start of the design program the operator must supply the following initial data:

- automatic or manual operation
- name of set-up file
- graphic displays on or off

For this example, automatic operation is proper. Manual operation allows the on-line observation and alteration of many parameters and is best suited for initial runs or trouble shooting if computer errors occur. The set-up files contain initial parameters which will become the default values. It may be edited to suit a particular set of initial conditions to speed up future data entry. Most of these values may be reset or defaulted as the program continues. Figure 5 shows a composite screen of initial data for a 2500 kW system.

| INPUT POWER PLANT DATA | | HIT <CR> TO SELECT DEFAULT VALUE | |
|---|------|----------------------------------|------|
| POWERPLANT SIZE, kW | 2500 | REFORMER INLET degF | 1200 |
| INVERTER EFFICIENCY - % | 1 | REFORMER EXIT degF | 1550 |
| MECHANICAL EFFICIENCY - % | .95 | REFORM OFFSET degF | 150 |
| SYSTEM PRESSURE - atm | 6 | SHIFT OFFSET degF | 50 |
| DATA FOR DIESEL FUEL: | | HIGHER HEATING VALUE = 19350 | |
| LOWER HEATING VALUE - 18300 BTU/lb | | AVERAGE MOLECULAR WT = 204 | |
| WATER TO CARBON RATIO | | 3.5 INPUT UPDATE? | |
| IDM FUEL CELL: | | | |
| INPUT CELL VOLTAGE - volts | .7 | INPUT UPDATE? | |
| INPUT ANODE INLET TEMPERATURE - deg F | 220 | INPUT UPDATE? | |
| INPUT CATHODE INLET TEMPERATURE - deg F | 220 | INPUT UPDATE? | |
| INPUT OXYGEN UTILIZATION | .6 | INPUT UPDATE? | |
| INPUT HYDROGEN UTILIZATION | .85 | INPUT UPDATE? | |
| INPUT CELL TEMPERATURE | 238 | INPUT UPDATE? | |
| INPUT REFORMER PRESSURE | 6 | INPUT UPDATE? | |

Figure 5. Initial data screen display, DTRC7-R5.

Figure 6 shows a summary of the initially assumed conditions used by the computer prior to entering the material/energy balance routines as it appears on the operator's console.

| DTRC7-R4 PLANT PERFORMANCE DATA | | | |
|---------------------------------|-------------|----------------------|------------------------|
| OVERALL EFFICIENCY | | 37.7 % | |
| POWER: | | CELL | |
| NET | 2512.1 kW | CURRENT DENSITY | 953.5 asf |
| GROSS | 2644.4 kW | CELL VOLTAGE | 0.700 volts |
| FUEL CELL | 2644.4 kW | OPEN CIRCUIT (dH/nF) | 1.239 volts |
| INVERTER | 0.0 kW | CELL AREA | 3961.7 ft ² |
| PARASITE | 132.2 kW | ENERGY IN | |
| UTILIZATION: | | H(7) AIR IN= | 6.3E+06BTU/HR |
| FUEL | 0.850 | H(1) FUEL IN= | 3.0E+06BTU/HR |
| OXYGEN | 0.717 | OIL HTR IN= | -1.7E+03BTU/HR |
| TEMPERATURE: | | COMP SHAFT IN= | 5.2E+05BTU/HR |
| ANODE INLET | 262.2 deg F | ENERGY OUT= | 2.8E+06BTU/HR |
| CATHODE INLET | 244.7 deg F | H(32) GAS OUT= | 6.1E+06BTU/HR |
| CELL EXIT | 261.0 deg F | P(GROSS) OUT= | -1.9E+07BTU/HR |
| | | MAIN HX OUT= | 9.0E+06BTU/HR |
| | | TURB SHAFT OUT= | 5.0E+06BTU/HR |
| | | MAIN COND OUT= | 6.4E+06BTU/HR |
| | | ATR REGEN EFF | 0.89 |

Figure 6. Initial conditions display screen.

After the material/energy balance is complete, it is possible to obtain a listing of the temperatures, pressures, and composition at almost all nodes (refer to Figure 3). The entire listing is too comprehensive to include in this report as it produces several pages in fine print, however Figure 7 contains a truncated sample of the node array produced while running this design program demonstration.

| MICROFLO NODE ARRAY | | | | | | | | | | |
|---------------------|------------|------------|------------|------------|------------|------------|-----------|-----------|-----------|------------|
| NODE | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| H2 | 0.000 | 0.000 | 0.000 | 16.714 | 17.571 | 3.098 | 0.000 | 0.000 | 0.000 | 0.000 |
| H2O | 0.000 | 0.000 | 40.804 | 26.453 | 34.959 | 41.097 | 0.000 | 0.000 | 0.000 | 22.680 |
| CH4 | 0.000 | 0.000 | 0.000 | 0.001 | 0.001 | 0.001 | 0.000 | 0.000 | 0.000 | 0.000 |
| CO | 0.000 | 0.000 | 0.000 | 4.364 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| CO2 | 0.000 | 0.000 | 0.000 | 5.675 | 8.340 | 9.804 | 0.000 | 0.000 | 0.000 | 0.000 |
| O2 | 0.000 | 0.000 | 4.080 | 0.000 | 0.000 | 0.000 | 20.950 | 20.950 | 20.950 | 16.198 |
| N2 | 0.000 | 0.000 | 54.338 | 46.793 | 39.129 | 46.000 | 79.050 | 79.050 | 79.050 | 61.121 |
| No. 2 FO | 100.000 | 100.000 | 0.777 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| TOTAL | 5.821 | 5.821 | 748.940 | 869.704 | 1040.042 | 884.705 | 797.269 | 797.269 | 282.455 | 665.826 |
| T DEG F | 70 | 70 | 1298 | 1550 | 262 | 261 | 70 | 575 | 575 | 245 |
| P ATM | 6.000 | 47.619 | 6.000 | 6.000 | 6.000 | 6.000 | 1.000 | 6.000 | 6.000 | 6.000 |
| H BTU/HR | -1.606E+03 | -1.373E+05 | -2.021E+07 | -2.021E+07 | -4.648E+07 | -4.725E+07 | 2.983E+06 | 5.806E+06 | 2.057E+06 | -1.213E+07 |
| S BTU/HR F | -1.333E+02 | -4.133E+02 | 3.989E+04 | 4.539E+04 | 4.594E+04 | 3.960E+04 | 3.553E+04 | 3.645E+04 | 1.291E+04 | 2.936E+04 |
| CP B/HR F | 3.982E+02 | 5.696E+02 | 7.980E+03 | 7.633E+03 | 7.939E+03 | 6.861E+03 | 5.553E+03 | 5.751E+03 | 2.038E+03 | 4.847E+03 |

Figure 7. Sample node array of the system design module DTRC7-R5.

Heat Exchanger Modules, HXNET-1B, HXNET-2B, and HXNET-3B.

The program automatically starts the heat exchanger design programs after conclusion of the system design module DTRC7-R5. The operator has the option of automatic or manual control. Automatic control is preferable with the manual mode chosen only for special conditions or trouble shooting in case of program error. The operator can change or default the heat exchange coefficients for nine models depending on the heat transfer technology. Most of the default coefficients are for a standard shell and tube arrangement. The exception is the hot gas heat exchanger (heat exchanger #1) in Figure 8), which is a plate type.

During the operation of this module the energy balance is revisited and a special routine selects and positions heat exchangers for maximum efficiency. At the conclusion a system map similar to that shown in Figure 8 is produced showing the position of each numbered heat exchanger relative to the nodes. The design data for each heat exchanger is manually selectable and appears similar to the sample shown in Figure 9.




Figure 8. Heat exchanger design output matrix.

During the heat exchanger design program execution, the operator is given the opportunity to bypass the graphics mode. This is a preferred choice when generating several design variants where the basic heat exchanger layout would not be expected to change with input requirements. At the conclusion of the heat exchanger programs all pertinent data is automatically recorded in a disk file for use in the subsequent weight/volume and off-design programs.




Figure 9. Typical heat exchanger design output screen.

Cost Estimating. ECON7.

The cost module is quite comprehensive being based on the requirements of power production industry and includes many aspects not pertinent to naval applications. It is arranged in a logical procedure and draws from an established

data base. Several screens of data are presented from which the operator can glean the information pertinent to his requirements.

The operator has the opportunity to modify several cost parameters, the first of which is the cost of the cell components in dollars per square foot of cell hardware. This is very important in light of the ever decreasing costs as development continues. As the program executes many other screens are presented with various options for the operator. A typical set of screens is shown in Figures 10 through 13.

The first screen, Figure 10, allows the operator to vary the process contingency factors of selected cost items based of the maturity of the technology. Suggested percentages are listed at the bottom. For this example, all items will be assigned the default value for "small pilot plant data" of 20 percent.

| ASSIGN CONTINGENCIES | | | |
|--------------------------------|----|----------|------------------------------|
| FUEL CELL POWER SECTION | \$ | 478,895. | < |
| FUEL PROCESSING | \$ | 373,063. | |
| CONDENSER EQUIPMENT | \$ | 413. | |
| HEAT EXCHANGERS | \$ | 35,206. | |
| GAS CLEANUP | \$ | 77,884. | |
| POWER CONDITIONING | \$ | 0. | |
| LOX PRODUCTION | \$ | 0. | |
| TURBINES & COMPRESSORS | \$ | 126,423. | |
| STEAM TURB. & GEN. | \$ | 0. | |
| INSTRUMENT. & CONTROL | \$ | 136,498. | |
| STRUCTURES & PLUMBING | \$ | 136,498. | |
| GENERAL FACILITIES | \$ | 68,795. | |
| PROCESS CONTINGENCIES | | | |
| NEW PROCESS - LIMITED DATA.... | 40 | % | |
| CONCEPT - BENCH SCALE DATA.... | 30 | % | |
| SMALL PILOT PLANT DATA..... | 20 | % | |
| FULL SCALE PLANT OPERATED..... | 5 | % | |
| COMMERCIALIZED..... | 0 | % | |
| ASSIGN PROCESS CONTINGENCY | 20 | % | |
| | | | ANALYTIC POWER CONTINGENCIES |

Figure 10. Example of process contingency cost screen.

After this is accomplished, a second screen is presented allowing the operator to assign an overall project contingency. In this example, the default value for a "preliminary" plant with a value of 15 percent will be accepted.

| ASSIGN CONTINGENCIES | | | |
|-----------------------------|----|----------|-------------|
| FUEL CELL POWER SECTION | \$ | 478,895. | \$ 574,794. |
| FUEL PROCESSING | \$ | 373,063. | \$ 447,675. |
| CONDENSER EQUIPMENT | \$ | 413. | \$ 413. |
| HEAT EXCHANGERS | \$ | 35,206. | \$ 35,206. |
| GAS CLEANUP | \$ | 77,884. | \$ 77,884. |
| POWER CONDITIONING | \$ | 0. | \$ 0. |
| LOX PRODUCTION | \$ | 0. | \$ 0. |
| TURBINES & COMPRESSORS | \$ | 126,423. | \$ 126,423. |
| STEAM TURB. & GEN. | \$ | 0. | \$ 0. |
| INSTRUMENT. & CONTROL | \$ | 136,498. | \$ 136,498. |
| STRUCTURES & PLUMBING | \$ | 136,498. | \$ 136,498. |
| GENERAL FACILITIES | \$ | 68,795. | \$ 68,795. |
| PROJECT CONTINGENCIES | | | |
| SIMPLIFIED DESCRIPTION..... | 30 | % | |
| PRELIMINARY..... | 15 | % | |
| DETAILED..... | 10 | % | |
| FINALIZED..... | 5 | % | |
| ASSIGN PROJECT CONTINGENCY | 15 | % | |

Figure 11. Example of project contingency cost screen.

After all contingencies are assigned, a summary of the costs, Figure 12, is displayed. The operator may extract selected data from this display, or the program may be amended to allow automatic recording of the selected data in a data file.

| | CAPITAL COST | CC+PROC CONT. | CC+ALL CONT. |
|-------------------------|-------------------|-------------------|-------------------|
| FUEL CELL POWER SECTION | \$ 192.30 /KW | \$ 230.76 /KW | \$ 265.37 /KW |
| FUEL PROCESSING | \$ 149.77 /KW | \$ 179.73 /KW | \$ 206.68 /KW |
| CONDENSER EQUIPMENT | \$ 0.17 /KW | \$ 0.17 /KW | \$ 0.19 /KW |
| HEAT EXCHANGERS | \$ 14.13 /KW | \$ 14.13 /KW | \$ 16.25 /KW |
| GAS CLEANUP | \$ 31.27 /KW | \$ 31.27 /KW | \$ 35.86 /KW |
| POWER CONDITIONING | \$ 0.00 /KW | \$ 0.00 /KW | \$ 0.00 /KW |
| LOX PRODUCTION | \$ 0.00 /KW | \$ 0.00 /KW | \$ 0.00 /KW |
| TURBINES & COMPRESSORS | \$ 50.75 /KW | \$ 50.75 /KW | \$ 58.37 /KW |
| STEAM TURB. & GEN. | \$ 0.00 /KW | \$ 0.00 /KW | \$ 0.00 /KW |
| INSTRUMENT. & CONTROL | \$ 54.80 /KW | \$ 54.80 /KW | \$ 63.02 /KW |
| STRUCTURES & PLUMBING | \$ 54.80 /KW | \$ 54.80 /KW | \$ 63.02 /KW |
| GENERAL FACILITIES | \$ 27.62 /KW | \$ 27.62 /KW | \$ 31.76 /KW |
| TOTAL | \$ 575.61 /KW | \$ 644.02 /KW | \$ 740.63 /KW |

Figure 12. Example of the contingency cost summary screen.

Figure 13 is a representation of the cost summary screen on which all the major cost categories are displayed. The cost module continues after this screen to estimate the costs for industrial depreciation etc. which are not of use in our investigations but must be executed to obtain a proper exit from the program.

| PLANT COST SUMMARY | | |
|-----------------------------------|----------------|----------------|
| TOTAL PLANT CAPITAL | | \$ 712.60 /KW |
| INSTALLATION COST | | \$ 213.78 /KW |
| ENGR & HOME OFFICE | | \$ 213.78 /KW |
| PROCESS CONTINGENCIES | | \$ 68.41 /KW |
| PROJECT CONTINGENCIES | | \$ 117.15 /KW |
| TOTAL PLANT COST | \$1,325.73 /KW | |
| TOTAL PLANT INVESTMENT | \$1,453.00 /KW | |
| START UP COST | | |
| PREPAID ROYALTIES | | \$ 7.27 /KW |
| ONE MONTH FIXED OPERATING COST | | \$ 4.29 /KW |
| ONE MONTH VARIABLE OPERATING COST | | \$ 25.51 /KW |
| START UP COST | | \$ 66.12 /KW |
| TOTAL CAPITAL REQUIREMENT | | \$1,519.12 /KW |

Figure 13. Example of cost summary screen.

Determining component and system weights and volumes. WT-VOL7

This module is the culmination of the design efforts of the programs up to this point. It is entered automatically at the conclusion of the ECON module. The operator must first decide what packing factor to use. The default value, and the one almost universally utilized in past studies, is 1.5. This value represents the additional volume required for walkways, maintenance spaces, pipe bends and flanges, and other possible contingencies. Figure 14 represents the first output data screen in a series of four. It contains a summation of the system weight data.

| SYSTEM WEIGHT ANALYSIS | | | |
|--------------------------|----------------------|--------------------------|--------------------------|
| APPLICATION: 1.0 mW | | OPERATING TIME: 24.0 hrs | |
| NET POWER: 2490.882 KW | | CELL TYPE: IEMFC | |
| (TONS) | FUEL CELL (NO2FO) | GAS TURBINE (NO2FO) | DIESEL ENGINE (NO2FO) |
| POWER SECTION | 2.0 | 25.3 | 24.4 |
| INVERTER | 0.1 | N/A | N/A |
| HEAT EXCHANGERS | 1.0 | N/A | N/A |
| B.O.P. | 5.9 | N/A | N/A |
| SUBTOT | 9.0 | 25.3 | 24.4 |
| SPECIFIC WT. lb/kw | 8.1 | 22.9 | 22.1 |
| FUEL | 12.7 | 13.4 | 11.8 |
| TOTAL | 21.6 | 38.7 | 36.2 |
| SPECIFIC WEIGHT (lb/kWh) | 0.81 | 1.46 | 1.36 |

Figure 14. Example of system weight summary screen.

The screen containing the system volume summary follows immediately and appears as shown in Figure 15.

| SYSTEM VOLUME ANALYSIS | | | |
|---------------------------|----------------------|--------------------------|--------------------------|
| APPLICATION: 1.0 mW | | OPERATING TIME: 24.0 hrs | |
| NET POWER: 2490.882 KW | | CELL TYPE: IEMFC | |
| (FT3) | FUEL CELL (NO2FO) | GAS TURBINE (NO2FO) | DIESEL ENGINE (NO2FO) |
| POWER SECTION | 140.7 | 1985.5 | 1878.2 |
| INVERTER | 10.6 | N/A | N/A |
| HEAT EXCHANGERS | 69.5 | N/A | N/A |
| B.O.P. | 180.8 | N/A | N/A |
| SUBTOTAL | 602.4 | 1985.5 | 1878.2 |
| SPECIFIC VOL. ft3/kw | 0.24 | 0.80 | 0.75 |
| FUEL | 528.6 | 557.8 | 491.2 |
| TOTAL | 1131.0 | 2543.3 | 2369.4 |
| SPECIFIC VOLUME (in3/kWh) | 32.69 | 73.51 | 68.49 |

Figure 15. Example of the system volume summary screen.

The next two screens give weight and volume details of the balance of plant. Figure 16 shows the data display screen for the heat exchangers for the current sample 2500kW sample fuel cell system. In the sample case only two heat exchangers are required. In other cases, as many as nine heat exchangers are required and will be displayed in a similar manner as those shown.

| HEAT EXCHANGERS | | | |
|--------------------|------------|--------------|--------------|
| | AREA (ft2) | WEIGHT (lbs) | VOLUME (ft3) |
| HEAT EXCHANGER # 1 | 3116.2 | 1306.3 | 36.2 |
| HEAT EXCHANGER # 2 | 141.4 | 971.2 | 33.4 |
| TOTAL 1- 2 | | 2277.5 | 69.5 |

Figure 16. Example of heat exchanger weight and volume analysis.

The balance of plant detailed analysis, as shown in Figure 17, contains data on the balance of plant including the reformer, shift converter, and desulfurizing equipment. The HDS refers to a hydrodesulfurizer unit which is required for some technologies which use steam reforming. It is not required for ATR operation.

| BALANCE OF PLANT | | |
|------------------|------------|---------------------------|
| | AREA (ft2) | WEIGHT (lbs) VOLUME (ft3) |
| TOTAL 1- 0 | | 0.0 0.0 |
| REFORMER | | 3939.9 65.7 |
| SHIFT CONVERTER | | 6646.9 79.6 |
| HDS | | 0.0 0.0 |
| ZNO BED | | 2607.2 35.5 |

Figure 17. Example of balance of plant weight and volume analysis.

The ZnO beds in this sample run are sized to continuously desulfurize fuel at the maximum rate for the plant assuming a sulfur content of 0.5 percent. They consist of two beds, one processing anode gases while the other is regenerated with a small flow of air. The beds are reversed on a 24 hour cycle.

This is a conservative estimate at this time. Inquiries are being made in the field of new, more efficient adsorption media. More efficient absorbers will lower the associated weight and volume. The new higher standards of air quality are causing refineries to produce ever lower sulfur content in their marketable fuels. By the time fuel cell power systems technology reaches mass production capacity in a few years, these future fuels will also decrease the impact on on-board sulfur removal equipment.

Off-Design Module Operation, DTRC7-OD.

After the design of the fuel cell power system has been completed, the operator may run the off-design module to obtain specific fuel capacities at various loads. This is an independent program which must be run separately. It uses data automatically filed during the running of the design modules. It is best to run this module immediately following DTRC7-R5 so that there will be no question as to the validity of the input data. Figure 18 shows an example of the set-up screen displayed after a net power of 50 percent of full load (1250 kW) is requested.

| IEMFC PLANT PERFORMANCE DATA | | | |
|------------------------------|-------------|----------------------|-----------------|
| OVERALL EFFICIENCY | 41.9 % | | |
| POWER: | | CURRENT DENSITY | 442.2 asf |
| NET | 1250.0 kW | CELL VOLTAGE | 0.786 volts |
| GROSS | 1376.4 kW | OPEN CIRCUIT (dH/mF) | 1.227 volts |
| FUEL CELL | 1204.3 kW | CELL AREA | 3961.7 ft2 |
| INVERTER | 0.0 kW | | |
| PARASITE | 110.6 kW | | |
| UTILIZATION: | | HEAT: | |
| FUEL | 0.850 | BURNER | -4.1E+06 btu/hr |
| HYDROGEN | 0.850 | | |
| OXYGEN | 0.710 | | |
| TEMPERATURE: | | | |
| ANODE INLET | 253.5 deg F | | |
| CATODE INLET | 231.4 deg F | | |
| CELL EXIT | 238.0 deg F | | |

Figure 18. Example of the set-up screen for off-design analysis.

Differences in the data between the original design, Figure 6, and the off-design data, Figure 18, are as follows:

- the net power is exactly as requested, half of the full load or 1250 kW
- the efficiency is higher, 41.9 percent compared to 37.7 percent
- temperatures are reduced
- cell voltage is higher due to a lower current density
- oxygen utilization is increased while fuel utilization is held constant

Figure 19 contains the summary of the output data from the off-design program module. The most significant variable is the fuel rate given in pound moles per hour (MPH). Using the average molecular weight of the fuel, 204.19 lb/lb mole for diesel fuel, the specific fuel consumption versus load curve, Figure 1, can be obtained.

| | |
|-------------------------------|-------------------|
| OFF-DESIGN NET POWER | 1250.00 KW |
| OFF-DESIGN GROSS POWER | 1376.40 KW |
| OFF-DESIGN OVERALL EFFICIENCY | 0.42 |
| DESIGN OVERALL EFFICIENCY | 0.38 |
| MECHANICAL EFFICIENCY | 0.91 |
| CURRENT DENSITY | 442.17 ASF |
| CELL VOLTAGE | 0.79 VOLTS |
| TOTAL AREA | 3961.72 SQ FT |
| MOLECULAR WT OF FUEL | 204.19 LB/LBMOL |
| FUEL FLOW | 2.73 MPH |
| FC STACK EFFICIENCY | 0.64 |
| FC THEORETICAL VOLTAGE | 1.23 VOLTS |
| TAFEL SLOPE | 0.06 VOLTS/DECADE |
| WASTE GATE | 0.00 |
| FUEL ADDITION | 0.05 MPH |

Figure 19. Example of the off-design data summary screen.

The datum referred to as "WASTE GATE" is a programming artifact to allow for energy and material overflow during program operation and is somewhat analogous to a gas by-pass of the stack during transient operation, eg. start-up, shut-down, and load change. It has no meaning at steady-state conditions (Except possibly during completely unloaded conditions).

As the load on a given fuel cell system is reduced the overall thermal efficiency increases, and there is less energy available in the spent anolyte gas to power the turbine. Therefore some fuel must bypass the stack and be mixed with the spent anolyte gas ahead of the burner. The FUEL ADDITION variable refers to the fraction of total fuel representative of the additional energy. This fuel is included in the FUEL FLOW variable and is broken out in the table for analysis purposes.

The TAFEL SLOPE is a variable used in computing the fuel cell polarization curve. It is shown for analytic purposes only and is of limited use in the context of this report.

3-D MODELING BY COMPUTER AIDED DESIGN

At the conclusion of the analytical design programs sufficient data is available to produce three-dimensional models with an appropriate computer aided design (CAD) program. The model shown in Figure 20 was produced using AutoCad™ (release 12) from the data obtained during the sample design and analysis. The model may be combined with other models such as that for a ship, to check the fit

2500 kW Fuel Cell Power System




Figure 20. 3-dimensional model of the 2500 kW fuel cell power system.

of components, or to aid in visualizing installations within allotted spaces with the capability to readjust component positions for economy of space. 3-D modeling also allows realistic comparisons of fuel cell systems with other electric power plants.

CONCLUSIONS

The computer modeling programs available at the Annapolis Detachment, Carderock Division, NSWC are extremely versatile and effective in determining the design parameters for PEM, PAFC, and MCFC power systems up to 50 MW. It is very probable that larger power systems can be analyzed without modification although this has not been attempted to date. Although cell components for 10kW stacks have been verified, the BOP of these small power systems, in the range of 10 kW and below, may be suspect as scaling factors for such small equipment are sensitive to unspecifiable form factors, such as the radiant heat losses from an unspecifiable shape, and flow factors in piping which, in actuality, may have numerous acute bends which are unpredictable or at least unspecified.

The programs and modules covered in the above description can be used to obtain the following parametric data for the design of many fuel cell systems:

- Cell design active area
- Stack design including the number of cells, weight, and volume
- Balance of plant weight and volume including;
 - reformer
 - shift converter
 - condensers
 - heat exchangers
 - sulfur adsorbers
 - pumps, blowers, and motors

The heat balance and heat exchanger analysis module is ideal for designing the complex arrays required for realizing the fuel economy fuel cell technology permits. This gives the designer the advantage of concentrating on the aspects of ubiquitous fuel cell system design without having to dilute their efforts with tedious heat balance and heat exchanger design.

The principal caveat revealed in this study is that no diesel fuel powered fuel cell system has been built to date that can be used to validate the results of the programs. Until this is accomplished, all the design data generated with these modules must be considered as theoretical. Only the PAFC module has been validated against an industrial facsimile. A comparison of the design data from the PAFC module run corresponded well with the design of the ONSI[™] PC25, a commercially available 200kW PAFC system using natural gas.

RECOMMENDATIONS

Continuous updating of the existing modules to reflect the ever changing state of the art in fuel cell development is strongly recommended. Examples of these modifications are:

- addition of bottoming cycles to exploit all available energy
- updated data for heat exchanger designs and materials
- optimized heat balance routines for maximizing water recovery.

It is recommended that a contract to generate a design module specific to solid oxide technology be initiated as soon as possible. This would enhance the present effort in assessing and analyzing future systems incorporating this promising technology.

APPENDIX A: Example of PEM design data for ship impact study

POLYMER EXCHANGE TECHNOLOGY FUEL CELL SYSTEMS

| CORVETTE 2100 PROPULSION | | | | | | | | | | | |
|--------------------------|----------|---------|---------|---------|----------|----------|----------|----------|----------|----------|------|
| Nominal Power, MWatt | | 9 | | | 10 | | | 11 | | | |
| Cell Design Voltage | | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | |
| Net Power | kWatts | 9043.79 | 9043.72 | 9043.71 | 10047.64 | 10047.63 | 10047.63 | 11053.49 | 11054.50 | 11053.51 | 0.80 |
| Air Flow | SCFS | 286.26 | 267.18 | 250.48 | 318.04 | 296.83 | 296.83 | 349.87 | 326.58 | 306.14 | 0.75 |
| Exhaust Flow | SCFS | 299.12 | 278.18 | 261.73 | 332.32 | 310.17 | 310.17 | 365.59 | 341.25 | 319.89 | 0.70 |
| Exhaust Temp | Deg. F. | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 0.65 |
| Sea H2O | GPM | 1495.12 | 1395.44 | 1308.22 | 1661.08 | 1550.34 | 1550.34 | 1827.36 | 1705.69 | 1598.95 | 0.60 |
| Potable H2O | GPM | 8.64 | 8.07 | 7.56 | 9.60 | 8.96 | 8.96 | 10.56 | 9.86 | 9.24 | 0.55 |
| Cost: Fuel Cell | \$ / kW | 265.20 | 312.34 | 387.88 | 265.19 | 312.34 | 312.34 | 265.18 | 312.33 | 387.89 | 0.50 |
| : BOP | \$ / kW | 359.57 | 362.76 | 346.93 | 351.00 | 354.44 | 354.44 | 343.56 | 347.21 | 358.71 | 0.45 |
| Fuel Cell Wt | Ltons | 7.12 | 8.40 | 10.44 | 7.91 | 9.33 | 9.33 | 8.70 | 10.27 | 12.76 | 0.40 |
| Fuel Cell Vol | Cu. Ft | 759.48 | 895.61 | 1113.68 | 843.77 | 995.14 | 995.14 | 928.16 | 1094.86 | 1361.29 | 0.35 |
| BOP Wt | Ltons | 13.20 | 12.61 | 11.99 | 14.16 | 13.52 | 13.52 | 15.10 | 14.41 | 13.80 | 0.30 |
| Desulfurizer Wt | Ltons | 1.39 | 3.89 | 3.65 | 4.63 | 4.33 | 4.33 | 5.10 | 4.76 | 4.46 | 0.25 |
| BOP Vol | Cu. Ft. | 695.38 | 665.58 | 620.41 | 743.96 | 711.70 | 711.70 | 791.40 | 756.80 | 725.91 | 0.20 |
| Desulfurizer Vol | Cu. Ft. | 63.85 | 178.79 | 167.62 | 212.82 | 198.64 | 198.64 | 234.13 | 218.54 | 204.87 | 0.15 |
| Fuel, 125% | Lb/kW-hr | 0.4804 | 0.4631 | 0.4460 | 0.4804 | 0.4631 | 0.4631 | 0.4804 | 0.4631 | 0.4460 | 0.10 |
| 100% | Lb/kW-hr | 0.4633 | 0.4507 | 0.4377 | 0.4633 | 0.4507 | 0.4507 | 0.4633 | 0.4507 | 0.4377 | 0.05 |
| 75% | Lb/kW-hr | 0.4509 | 0.4418 | 0.4321 | 0.4509 | 0.4418 | 0.4418 | 0.4509 | 0.4418 | 0.4321 | 0.00 |
| 50% | Lb/kW-hr | 0.4451 | 0.4388 | 0.4316 | 0.4451 | 0.4388 | 0.4388 | 0.4451 | 0.4388 | 0.4316 | 0.00 |
| 25% | Lb/kW-hr | 0.4585 | 0.4542 | 0.4491 | 0.4585 | 0.4542 | 0.4542 | 0.4585 | 0.4542 | 0.4491 | 0.00 |

CORVETTE 2100 SHIP SYSTEM GENERATOR

| CORVETTE 2100 SHIP SYSTEM GENERATOR | | | | | | | | | | | |
|-------------------------------------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|------|
| Nominal Power, kWatt | | 400 | | | 500 | | | 600 | | | |
| Cell Design Voltage | | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | |
| Net Power | kWatts | 401.94 | 401.94 | 401.94 | 502.43 | 502.43 | 502.43 | 602.91 | 602.91 | 602.91 | 0.80 |
| Air Flow | SCFS | 12.72 | 11.87 | 11.13 | 15.90 | 14.84 | 13.92 | 19.08 | 17.81 | 16.70 | 0.75 |
| Exhaust Flow | SCFS | 13.29 | 12.41 | 11.63 | 16.62 | 15.51 | 14.54 | 19.94 | 18.61 | 17.45 | 0.70 |
| Exhaust Temp | Deg. F. | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 150.00 | 0.65 |
| Sea H2O | GPM | 66.45 | 62.02 | 58.14 | 83.06 | 77.52 | 72.68 | 99.67 | 93.03 | 87.21 | 0.60 |
| Potable H2O | GPM | 0.38 | 0.36 | 0.34 | 0.48 | 0.45 | 0.42 | 0.58 | 0.54 | 0.50 | 0.55 |
| Cost: Fuel Cell | \$ / kW | 265.87 | 312.98 | 388.50 | 265.79 | 312.91 | 388.41 | 265.72 | 312.84 | 388.37 | 0.50 |
| : BOP | \$ / kW | 871.01 | 860.53 | 859.18 | 799.89 | 791.59 | 792.19 | 746.98 | 740.30 | 742.36 | 0.45 |
| Fuel Cell Wt | Ltons | 0.32 | 0.37 | 0.46 | 0.40 | 0.47 | 0.58 | 0.48 | 0.56 | 0.70 | 0.40 |
| Fuel Cell Vol | Cu. Ft | 33.77 | 39.89 | 49.58 | 42.24 | 49.77 | 61.90 | 50.71 | 59.74 | 74.32 | 0.35 |
| BOP Wt | Ltons | 1.81 | 1.74 | 1.68 | 2.06 | 1.98 | 1.91 | 2.29 | 2.20 | 2.12 | 0.30 |
| Desulfurizer Wt | Ltons | 0.37 | 0.37 | 0.37 | 0.23 | 0.22 | 0.20 | 0.28 | 0.26 | 0.24 | 0.25 |
| BOP Vol | Cu. Ft. | 84.83 | 81.36 | 78.26 | 97.38 | 93.26 | 89.60 | 109.35 | 104.62 | 100.42 | 0.20 |
| Desulfurizer Vol | Cu. Ft. | 17.02 | 17.02 | 17.02 | 10.64 | 9.93 | 9.31 | 12.77 | 11.92 | 11.17 | 0.15 |
| Fuel, 125% | Lb/kW-hr | 0.4804 | 0.4631 | 0.4460 | 0.4804 | 0.4631 | 0.4460 | 0.4804 | 0.4631 | 0.4460 | 0.10 |
| 100% | Lb/kW-hr | 0.4633 | 0.4507 | 0.4377 | 0.4633 | 0.4507 | 0.4377 | 0.4633 | 0.4507 | 0.4377 | 0.05 |
| 75% | Lb/kW-hr | 0.4509 | 0.4418 | 0.4321 | 0.4509 | 0.4418 | 0.4321 | 0.4509 | 0.4418 | 0.4321 | 0.00 |
| 50% | Lb/kW-hr | 0.4444 | 0.4381 | 0.4309 | 0.4444 | 0.4381 | 0.4309 | 0.4444 | 0.4381 | 0.4309 | 0.00 |
| 25% | Lb/kW-hr | 0.4577 | 0.4534 | 0.4483 | 0.4577 | 0.4534 | 0.4483 | 0.4577 | 0.4534 | 0.4483 | 0.00 |

APPENDIX B: Example of PAFC design data for ship impact study

PHOSPHORIC ACID TECHNOLOGY FUEL CELL SYSTEMS

| CORVETTE 2100 PROPULSION | | | | | | | | | | | |
|--------------------------|----------|--|---------|---------|---------|---------|---------|----------|----------|----------|----------|
| Nominal Power, MWatt | | | 9 | | | 10 | | | 11 | | |
| Cell Design Voltage | | | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 |
| Net Power | kWatts | | 8610.87 | 8610.87 | 8610.87 | 9567.64 | 9567.63 | 9567.64 | 10524.40 | 10524.40 | 10524.40 |
| Air Flow | SCFS | | 255.74 | 238.69 | 223.77 | 284.15 | 265.21 | 248.63 | 312.57 | 291.73 | 273.50 |
| Exhaust Flow | SCFS | | 268.19 | 250.31 | 234.66 | 297.99 | 278.12 | 260.74 | 327.79 | 305.93 | 286.81 |
| Exhaust Temp | Deg. F. | | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 |
| Sea H2O | GPM | | 1905.70 | 1677.91 | 1478.60 | 2117.44 | 1864.34 | 1642.88 | 2329.19 | 2050.78 | 1807.17 |
| Potable H2O | GPM | | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Cost: Fuel Cell | \$ / kW | | 320.32 | 458.03 | 754.77 | 320.32 | 458.03 | 754.76 | 320.31 | 458.02 | 754.76 |
| : BOP | \$ / kW | | 488.21 | 500.18 | 558.30 | 482.83 | 494.06 | 556.02 | 476.41 | 491.83 | 550.51 |
| Fuel Cell Wt | Ltons | | 57.75 | 82.61 | 136.19 | 64.16 | 91.79 | 151.32 | 70.59 | 100.96 | 166.46 |
| Fuel Cell Vol | Cu. Ft | | 4190.17 | 5994.22 | 9882.14 | 4655.35 | 6660.12 | 10980.16 | 5121.71 | 7326.01 | 12078.17 |
| BOP Wt | Ltons | | 31.57 | 29.01 | 27.79 | 34.12 | 31.09 | 30.61 | 35.93 | 33.74 | 31.65 |
| Desulfurizer Wt | Ltons | | 6.97 | 6.97 | 6.97 | 7.48 | 7.48 | 7.48 | 7.97 | 7.97 | 7.97 |
| BOP Vol | Cu. Ft | | 1834.44 | 1731.55 | 1672.82 | 1939.65 | 1824.94 | 1783.95 | 2021.68 | 1931.43 | 1844.36 |
| Desulfurizer Vol | Cu. Ft | | 341.67 | 341.67 | 341.67 | 366.95 | 366.95 | 366.95 | 391.48 | 391.48 | 391.48 |
| Fuel, 125% | Lb/kW-hr | | 0.6237 | 0.5940 | 0.5680 | 0.6237 | 0.5940 | 0.5680 | 0.6237 | 0.5940 | 0.5680 |
| 100% | Lb/kW-hr | | 0.4456 | 0.4159 | 0.3899 | 0.4456 | 0.4159 | 0.3899 | 0.4456 | 0.4159 | 0.3899 |
| 75% | Lb/kW-hr | | 0.3959 | 0.3662 | 0.3402 | 0.3959 | 0.3662 | 0.3402 | 0.3959 | 0.3662 | 0.3402 |
| 50% | Lb/kW-hr | | 0.5453 | 0.5156 | 0.4896 | 0.5453 | 0.5156 | 0.4896 | 0.5453 | 0.5156 | 0.4896 |
| 25% | Lb/kW-hr | | 1.0802 | 1.0505 | 1.0245 | 1.0802 | 1.0505 | 1.0245 | 1.0802 | 1.0505 | 1.0245 |

| CORVETTE 2100 SHIP SYSTEM GENERATOR | | | | | | | | | | | |
|-------------------------------------|----------|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Nominal Power, kWatt | | | 400 | | | 500 | | | 600 | | |
| Cell Design Voltage | | | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 | 0.70 | 0.75 | 0.80 |
| Net Power | kWatts | | 382.71 | 382.71 | 382.71 | 478.38 | 478.38 | 478.38 | 574.06 | 574.06 | 574.06 |
| Air Flow | SCFS | | 11.37 | 10.61 | 9.95 | 14.21 | 13.26 | 12.43 | 17.05 | 15.91 | 14.92 |
| Exhaust Flow | SCFS | | 11.92 | 11.12 | 10.43 | 14.90 | 13.91 | 13.04 | 17.88 | 16.69 | 15.64 |
| Exhaust Temp | Deg. F. | | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 |
| Sea H2O | GPM | | 84.70 | 74.57 | 65.72 | 105.87 | 93.22 | 82.14 | 127.05 | 111.86 | 98.57 |
| Potable H2O | GPM | | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Cost: Fuel Cell | \$ / kW | | 320.61 | 458.31 | 755.03 | 320.58 | 458.27 | 755.00 | 320.55 | 458.25 | 754.98 |
| : BOP | \$ / kW | | 868.08 | 870.80 | 919.24 | 813.40 | 818.12 | 867.79 | 776.15 | 782.01 | 831.62 |
| Fuel Cell Wt | Ltons | | 2.57 | 3.68 | 6.05 | 3.22 | 4.60 | 7.57 | 3.86 | 5.52 | 9.08 |
| Fuel Cell Vol | Cu. Ft | | 186.54 | 266.83 | 439.21 | 233.77 | 334.13 | 549.01 | 279.82 | 400.24 | 658.81 |
| BOP Wt | Ltons | | 4.15 | 4.03 | 3.66 | 4.59 | 4.31 | 4.19 | 4.97 | 4.81 | 4.63 |
| Desulfurizer Wt | Ltons | | 0.80 | 0.80 | 0.79 | 0.94 | 0.94 | 0.93 | 1.07 | 1.07 | 1.06 |
| BOP Vol | Cu. Ft | | 308.17 | 299.71 | 268.30 | 340.44 | 318.66 | 310.64 | 366.38 | 355.95 | 343.42 |
| Desulfurizer Vol | Cu. Ft | | 38.99 | 38.99 | 38.79 | 45.72 | 45.58 | 45.46 | 52.07 | 51.91 | 51.77 |
| Fuel, 125% | Lb/kW-hr | | 0.6237 | 0.5940 | 0.5680 | 0.6237 | 0.5940 | 0.5680 | 0.6237 | 0.5940 | 0.5680 |
| 100% | Lb/kW-hr | | 0.4456 | 0.4159 | 0.3899 | 0.4456 | 0.4159 | 0.3899 | 0.4456 | 0.4159 | 0.3899 |
| 75% | Lb/kW-hr | | 0.3959 | 0.3662 | 0.3402 | 0.3959 | 0.3662 | 0.3402 | 0.3959 | 0.3662 | 0.3402 |
| 50% | Lb/kW-hr | | 0.5453 | 0.5156 | 0.4896 | 0.5453 | 0.5156 | 0.4896 | 0.5453 | 0.5156 | 0.4896 |
| 25% | Lb/kW-hr | | 1.0802 | 1.0505 | 1.0245 | 1.0802 | 1.0505 | 1.0245 | 1.0802 | 1.0505 | 1.0245 |

APPENDIX C: Example of MCFC design data for ship impact study

MOLTEM CARBONATE TECHNOLOGY FUEL CELL SYSTEMS

| DESTROYER 5239 PROPULSION | | | | | | | | | |
|---------------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| 6 ATM PRESSURE | | | | | | | | | |
| Nominal Power, MWatt | | 16 | | 18 | | 20 | | | |
| Cell Design Voltage | | 0.65 | 0.70 | 0.75 | 0.65 | 0.70 | 0.75 | 0.65 | 0.70 |
| Net Power | kWatts | 16000.00 | 16000.00 | 16000.00 | 18000.00 | 18000.00 | 18000.00 | 20000.00 | 20000.00 |
| Air Flow | SCFS | 662.98 | 628.32 | 605.33 | 745.85 | 706.86 | 681.00 | 828.72 | 785.40 |
| Exhaust Flow | SCFS | 670.99 | 635.96 | 612.65 | 754.87 | 715.45 | 689.23 | 838.74 | 794.95 |
| Exhaust Temp | Deg. F. | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 |
| Sea H2O | GPM | 5426.30 | 4925.70 | 4601.90 | 6104.60 | 5541.20 | 5177.10 | 6782.90 | 6156.60 |
| Potable H2O | GPM | | | | | | | | |
| Cost: Fuel Cell | \$ / kW | 80.66 | 90.14 | 106.11 | 80.66 | 90.14 | 106.11 | 80.66 | 90.14 |
| : BOP | \$ / kW | 512.67 | 469.92 | 480.04 | 512.67 | 470.41 | 481.60 | 512.67 | 470.41 |
| Fuel Cell Wt | Ltons | 223.46 | 250.58 | 10560.20 | 251.38 | 281.90 | 330.73 | 279.31 | 313.23 |
| Fuel Cell Vol | Cu. Ft | 8212.99 | 9209.46 | 10804.15 | 9239.61 | 10360.52 | 12154.57 | 10266.22 | 11511.58 |
| BOP Wt | Ltons | 47.38 | 44.78 | 42.38 | 52.98 | 50.02 | 47.44 | 58.57 | 55.25 |
| Desulfurizer Wt | Ltons | 13.88 | 13.74 | 13.87 | 15.49 | 15.33 | 15.47 | 17.10 | 16.92 |
| BOP Vol | Cu. Ft | 2470.07 | 2231.34 | 2210.39 | 2729.26 | 2467.81 | 2431.42 | 2988.45 | 2704.28 |
| Desulfurizer Vol | Cu. Ft | 946.37 | 940.65 | 953.33 | 1055.34 | 1048.88 | 1062.59 | 1164.31 | 1157.11 |
| Fuel, 125% | Lb/kW-hr | 0.62 | 0.62 | 0.62 | 0.62 | 0.59 | 0.55 | 0.62 | 0.59 |
| 100% | Lb/kW-hr | 0.4606 | 0.4366 | 0.4206 | 0.4606 | 0.4366 | 0.4206 | 0.4606 | 0.4366 |
| 75% | Lb/kW-hr | 0.4652 | 0.4438 | 0.4244 | 0.4652 | 0.4438 | 0.4244 | 0.4652 | 0.4438 |
| 50% | Lb/kW-hr | 0.5921 | 0.5579 | 0.5275 | 0.5921 | 0.5579 | 0.5275 | 0.5921 | 0.5579 |
| 25% | Lb/kW-hr | 1.0990 | 0.9874 | 0.8960 | 1.0990 | 0.9874 | 0.8960 | 1.0990 | 0.9874 |

DESTROYER 5200 SHIP SYSTEM GENERATOR

| DESTROYER 5200 SHIP SYSTEM GENERATOR | | | | | | | | | |
|--------------------------------------|----------|---------|---------|---------|---------|---------|---------|---------|---------|
| 6 ATM PRESSURE | | | | | | | | | |
| Nominal Power, kWatt | | 2300 | | 2500 | | 2700 | | | |
| Cell Design Voltage | | 0.65 | 0.70 | 0.75 | 0.65 | 0.70 | 0.75 | 0.65 | 0.70 |
| Net Power | kWatts | 2300.00 | 2300.00 | 2300.00 | 2500.00 | 2500.00 | 2500.00 | 2700.00 | 2700.00 |
| Air Flow | SCFS | 95.30 | 90.34 | 87.02 | 103.59 | 98.19 | 94.58 | 111.88 | 106.05 |
| Exhaust Flow | SCFS | 96.46 | 91.42 | 88.07 | 104.84 | 99.37 | 95.73 | 113.23 | 107.32 |
| Exhaust Temp | Deg. F. | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 | 300.00 |
| Sea H2O | GPM | 780.00 | 709.70 | 661.40 | 847.80 | 771.20 | 719.00 | 915.60 | 832.80 |
| Potable H2O | GPM | | | | | | | | |
| Cost: Fuel Cell | \$ / kW | 80.66 | 90.14 | 106.11 | 80.66 | 90.14 | 106.11 | 80.66 | 90.14 |
| : BOP | \$ / kW | 512.67 | 469.92 | 467.57 | 512.67 | 470.41 | 467.57 | 512.67 | 470.41 |
| Fuel Cell Wt | Ltons | 32.16 | 36.02 | 1428.28 | 34.95 | 39.15 | 45.93 | 37.74 | 42.28 |
| Fuel Cell Vol | Cu. Ft | 1180.70 | 1324.70 | 1553.76 | 1283.36 | 1439.80 | 1688.80 | 1386.02 | 1554.91 |
| BOP Wt | Ltons | 9.04 | 8.95 | 7.77 | 9.60 | 9.47 | 8.27 | 10.16 | 10.00 |
| Desulfurizer Wt | Ltons | 2.85 | 2.83 | 2.90 | 3.01 | 2.99 | 3.06 | 3.17 | 3.15 |
| BOP Vol | Cu. Ft | 694.61 | 611.50 | 696.30 | 720.53 | 635.15 | 718.40 | 746.45 | 658.80 |
| Desulfurizer Vol | Cu. Ft | 199.94 | 199.25 | 204.85 | 210.84 | 210.07 | 215.78 | 221.73 | 220.90 |
| Fuel, 125% | Lb/kW-hr | 0.62 | 0.62 | 0.62 | 0.62 | 0.59 | 0.55 | 0.62 | 0.59 |
| 100% | Lb/kW-hr | 0.46 | 0.44 | 0.42 | 0.46 | 0.44 | 0.42 | 0.46 | 0.44 |
| 75% | Lb/kW-hr | 0.4652 | 0.4438 | 0.4244 | 0.4652 | 0.4438 | 0.4244 | 0.4652 | 0.4438 |
| 50% | Lb/kW-hr | 0.5921 | 0.5579 | 0.5275 | 0.5921 | 0.5579 | 0.5275 | 0.5921 | 0.5579 |
| 25% | Lb/kW-hr | 1.0990 | 0.9874 | 0.8960 | 1.0990 | 0.9874 | 0.8960 | 1.0990 | 0.9874 |

INITIAL DISTRIBUTION

Copies

CENTER DISTRIBUTION

| | | Copies | Code | Name |
|---|---------------------------------|--------|--------|-----------------|
| 1 | ONR 4524 | | | |
| 3 | NAVSEA | 1 | 80 | Argiro |
| | 03R17 | 1 | 82 | Doyle |
| | 06KR12 (Dampier) | 1 | 824 | Adamson |
| | 03Z (Graham) | 1 | 824S | Braun |
| | | 5 | 824 | Smith |
| 1 | Band Lavis and Association Inc. | 5 | 824 | Woerner |
| | (Goubault) | 1 | 825 | |
| | | 2 | 852 | |
| 1 | Analytic Power Corporation | 2 | 22 | Ritter |
| | (D.Bloomfield) | 1 | 214 | Heidenreich |
| | | 1 | 3422.2 | TIC(A) |
| 1 | Arctic Energies | 2 | 3431 | Office Services |
| | (W.Kumm) | | | |